

PLANNING AND CODES ADMINISTRATION DEPARTMENT
220 SE GREEN STREET
LEE'S SUMMIT, MO 64063
(816) 969-1200 FAX (816) 969-1201

Inspection Summary

Permit #: PRCOM20141074, Building Permit - Commercial
Address: 3311 SW KESSLER DR, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Rated Assembly Inspection	Mark Harding	Partial	Monday, August 31, 2015

Partial Correction

1	LOWER LEVEL	UNITS FIRST LAYER APPROVED 2 HOUR CONDITIONS APPROVED 2ND LAYER ELEVATOR ROOM APPROVED 3RD AND FOURTH LAYER ELEVATOR ROOM FAILED DUE TO DUCT ELEVATION. STRUCTURAL BEAM STILL NEEDS PROTECTED.>>>1ST LAYER APPROVED.
		2 hour conditions approved
Corrective Action Required		
2	FOURTH FLOOR	4th ok towers 4th layer

Comments: