

PLANNING AND CODES ADMINISTRATION DEPARTMENT
220 SE GREEN STREET
LEE'S SUMMIT, MO 64063
(816) 969-1200 FAX (816) 969-1201

Inspection Summary

Permit #: PRCOM20151120, Building Permit - Commercial
Address: 1744 NW CHIPMAN RD, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
In-wall Inspection	John Borns	Passed	Tuesday, September 01, 2015

Comments: NEW LIGHT-GAUGE STEEL FRAMED WALL AT (Q.5)/(18) OK TO COVER WHEN READY. MC ELECTRICAL CABLE AND BOX TO BE SET IN BASE AT BOTTOM OF WALL FINISH.