

PLANNING AND CODES ADMINISTRATION DEPARTMENT
220 SE GREEN STREET
LEE'S SUMMIT, MO 64063
(816) 969-1200 FAX (816) 969-1201

Inspection Summary

Permit #: PRCOM20150014, Building Permit - Commercial
Address: 508 NW MURRAY RD, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Rated Assembly Inspection	John Borns	Partial	Tuesday, September 01, 2015
Partial Correction 1 Misc 1		1ST FLOOR: OK TO TAPE, MUD & FIRE-STOP: RATED CEILINGS AND WALLS AT ALL UNITS EXCEPT STAIRWELL WALLS. NO COMMON OR UTILITY AREAS PRE-ROCK: UNIT 113: GWB WALL AT DEAD SPACE ADJACENT TO CORRIDOR; UNIT 112: LID OF CLOSET AT EXT WALL; UNIT 132: CEILING ABOVE HVAC DUCT AT BR; UNITS 101 & 102: CORR WALL @ COAT CLO;	
Partial Correction 2 Misc 1		2ND FLOOR: OK TO TAPE, MUD & FIRE-STOP: - CORRIDOR CEILING AND WALLS ONE LAYER 5/8" TYPE X GWB - RATED CEILINGS AND WALLS AT ALL UNITS EXCEPT WALLS AT STAIRWELLS	
Partial Correction 3 Misc 1		3RD FLOOR: OK TO TAPE, MUD & FIRE-STOP ONE LAYER 5/8" TYPE X GWB AT: ELECT & DATA RMS WALLS; WALLS AND CEILINGS (EXCEPT SHOWER CEILINGS) AT UNITS 317; 318; 323; [314; 315; STAIRWELL WALLS NOT READY FOR INSPECTION	
Partial Correction 4 Misc 1		4TH FLOOR: OK TO TAPE, MUD & FIRE-STOP ONE LAYER 5/8" TYPE X GWB AT: ELECT & DATA RMS WALLS	

Comments: