

PLANNING AND CODES ADMINISTRATION DEPARTMENT
220 SE GREEN STREET
LEE'S SUMMIT, MO 64063
(816) 969-1200 FAX (816) 969-1201

Inspection Summary

Permit #: PRCOM20141077, Building Permit - Commercial
Address: 3341 SW KESSLER DR, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Commercial	Mark Harding	Not Ready	Tuesday, September 01, 2015

Corrective Action Required
1 Misc 1

PREROUGH WALK GARAGES AND GROUND FLOOR
NO HVAC STARTED
-2ND FLOOR INCOMPLETE HVA, NOT READY FOR INSPECTION

Comments: