

PLANNING AND CODES ADMINISTRATION DEPARTMENT
220 SE GREEN STREET
LEE'S SUMMIT, MO 64063
(816) 969-1200 FAX (816) 969-1201

Inspection Summary

Permit #: PRCOM20141074, Building Permit - Commercial
Address: 3311 SW KESSLER DR, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Above Ceiling Inspection	Mark Harding	Partial	Wednesday, September 02, 2015

Corrective Action Required

1	FIRST FLOOR	CORRIODR, D1
---	-------------	--------------

Corrective Action Required

2	SECOND FLOOR	CORRIDOR, D1
---	--------------	--------------

Corrective Action Required

3	THIRD FLOOR	CORRIODR,D1
---	-------------	-------------

Corrective Action Required

4	FOURTH FLOOR	INSTALL DAMPERS 4405-6 4412-4413 SECURE NM WITHIN 12" OF BOX
---	--------------	---

Comments: