

PLANNING AND CODES ADMINISTRATION DEPARTMENT  
220 SE GREEN STREET  
LEE'S SUMMIT, MO 64063  
(816) 969-1200 FAX (816) 969-1201

## Inspection Summary

---

Permit #: PRCOM20150014, Building Permit - Commercial  
Address: 508 NW MURRAY RD, LEES SUMMIT, MO 64081

---

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

---

Inspection:	Inspector:	Outcome:	Date:
<b>Rated Assembly Inspection</b>	John Borns	Partial	Thursday, September 03, 2015
Partial Correction 1       Misc 1		1ST FLOOR: OK TO TAPE, MUD & FIRE-STOP: RATED CEILINGS AND WALLS AT ALL UNITS EXCEPT STAIRWELL WALLS. NO COMMON OR UTILITY AREAS  PRE-ROCK: UNIT 113: GWB WALL AT DEAD SPACE ADJACENT TO CORRIDOR; UNIT 112: LID OF CLOSET AT EXT WALL; UNIT 132: CEILING ABOVE HVAC DUCT AT BR; UNITS 101 & 102: CORR WALL @ COAT CLO;	
Partial Correction 2       Misc 1		2ND FLOOR: OK TO TAPE, MUD & FIRE-STOP: - CORRIDOR CEILING AND WALLS ONE LAYER 5/8" TYPE X GWB - RATED CEILINGS AND WALLS AT ALL UNITS EXCEPT WALLS AT STAIRWELLS	
Partial Correction 3       Misc 1		3RD FLOOR: OK TO TAPE, MUD & FIRE-STOP ONE LAYER 5/8" TYPE X GWB AT: ELECT & DATA RMS WALLS. WALLS AND CEILINGS AT UNITS 314; 315; 317; 318; 323; <b>[302 EXCEPT CORR WALL @ ROOF DRAIN; 311; 321; 324; 327; 332*; 333;</b>	
		<b>* STAIRWELL WALLS NOT READY FOR INSPECTION</b>	
Partial Correction 4       Misc 1		4TH FLOOR: OK TO TAPE, MUD & FIRE-STOP ONE LAYER 5/8" TYPE X GWB AT: ELECT & DATA RMS WALLS	

**Comments:**