

PLANNING AND CODES ADMINISTRATION DEPARTMENT
220 SE GREEN STREET
LEE'S SUMMIT, MO 64063
(816) 969-1200 FAX (816) 969-1201

Inspection Summary

Permit #: PRCOM20150014, Building Permit - Commercial
Address: 508 NW MURRAY RD, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Rated Assembly Inspection	John Borns	Partial	Friday, September 04, 2015

Partial Correction

1 Misc 1

Partial Correction

2 Misc 1

Partial Correction

3 Misc 1

Rated Assembly Inspection	John Borns	Partial	Friday, September 04, 2015
----------------------------------	------------	---------	----------------------------

Partial Correction

1 Misc 1

Partial Correction

2 Misc 1

Partial Correction

3 Misc 1

1ST FLOOR:

2ND FLOOR:

3RD FLOOR: OK TO TAPE, MUD & FIRE-STOP ONE LAYER 5/8" TYPE X GWB AT: CORRIDOR CEILING; ELECT & DATA RMS WALLS. WALLS AND CEILINGS AT UNITS 314; 315; 317; 318; 323; 302 EXCEPT CORR WALL @ ROOF DRAIN; 311; 321; 324; 327; 332*; 333; **[313; CORRIDOR WALLS (FIRE CAULK REQUIRED AT RAW TOP EDGE) EXCEPT TWO LOCATIONS WHERE PERMANENT ROOF DRAIN IS IN PROGRESS;**

* STAIRWELL WALLS NOT READY FOR INSPECTION

Corrective Action Required

4 Misc 1

4TH FLOOR: OK TO TAPE, MUD & FIRE-STOP ONE LAYER 5/8" TYPE X GWB AT: ELECT & DATA RMS WALLS

