

PLANNING AND CODES ADMINISTRATION DEPARTMENT
220 SE GREEN STREET
LEE'S SUMMIT, MO 64063
(816) 969-1200 FAX (816) 969-1201

Inspection Summary

Permit #: PRCOM20141076, Building Permit - Commercial
Address: 3331 SW KESSLER DR, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Mark Harding Codes Commercial		Not Ready	Tuesday, September 08, 2015

Corrective Action Required

1	Misc 1	1-2 floors -fire alarm test failed. -no guard rails on exterior - no rear egress landings exits -install all dampers - all exterior gfcis, terminate all dryer , exhaust etc covers - handrails at stair towers incomplete. incomplete inspection
---	--------	--

Alarm Test	Michael Weissenbach	Not Ready	Tuesday, September 08, 2015
-------------------	------------------------	-----------	-----------------------------

Occupancy Inspection - Michael Fire	Weissenbach	Not Ready	Tuesday, September 08, 2015
--	-------------	-----------	-----------------------------

Occupancy Inspection - Hector Soto Planning		Not Ready	Tuesday, September 08, 2015
--	--	-----------	-----------------------------

Comments: