

PLANNING AND CODES ADMINISTRATION DEPARTMENT
220 SE GREEN STREET
LEE'S SUMMIT, MO 64063
(816) 969-1200 FAX (816) 969-1201

Inspection Summary

Permit #: PRCOM20151120, Building Permit - Commercial
Address: 1744 NW CHIPMAN RD, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Above Ceiling Inspection	John Borns	Partial	Friday, September 11, 2015

Partial Correction
1 Misc 1

OK TO COVER WHEN READY ACT CEILING FRAMING +
ABOVE-CEILING SYSTEMS EXCEPT AT SE CORNER WHERE
CONDITION OF ELECTRICAL BOXES AND SIGN INVERTER ARE TO
BE IMPROVED.

Comments: