

PLANNING AND CODES ADMINISTRATION DEPARTMENT
220 SE GREEN STREET
LEE'S SUMMIT, MO 64063
(816) 969-1200 FAX (816) 969-1201

Inspection Summary

Permit #: PRRES20150529, Building Permit - Residential
Address: 3328 SW JESSIE LN, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Electrical Service Inspection - Residential	Mike Copeland	Passed	Friday, September 11, 2015

Gas Service Inspection - Residential	Mike Copeland	Failed	Friday, September 11, 2015
---	---------------	--------	----------------------------

Corrective Action Required

1	Misc 1	-PRESSURE APPROVED
		-BOND GAS PIPE

All Rough Inspection - Residential	Mike Copeland	Failed	Friday, September 11, 2015
---	---------------	--------	----------------------------

Corrective Action Required

1	Misc 1	-install 100 lb. straps at garage -nail all holes in foundation straps -install anchor bolts within 12" of plate breaks -garage cold wall has no hold downs have engineer address -have engineer address stud framing. Supposed to be continuous from floor to ceiling -security block back doors -nail exterior corner studs 12" o.c. -install stud support in basement for point load for LVL beams -nail garage portal 3" o.c. per detail
		Do not insulate.

Comments: CLEAN STREET PLEASE