PLANNING AND CODES ADMINISTRATION DEPARTMENT 220 SE GREEN STREET LEE'S SUMMIT, MO 64063 (816) 969-1200 FAX (816) 969-1201

Inspection Summary

Permit #: PRRES20151681, Building Permit - Residential Address: 1312 NE ERNEST WAY, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection: Outcome: Date:

All Rough Inspection - Khanh Nguyen Failed Friday, September 11, 2015

Residential

Corrective Action Required

L Misc 1 -FIREBLOCKING THROUGHOUT: FB ALL WALL SPACE FROM

CEILING SPACE (JOIST AND FURRED-DOWN SPACE); FB WALL

VERTICALLY EVERY 10 FT

-PROTECT PVC AT BEDROOM AND BATH ROOM BOTTOM WALL

PLATES WITH BOCA PLATES

-PROTECT WIRING NEAR CEILING AT STAIR WALL

-INSTALL A CO/SMOKE DETECTOR OUTSIDE BEDROOM

-INSTALL A RECEPTACLE INSIDE THE MECHANICAL RM

-INSTALL A SEPARATE CIRCUIT FOR THE BATHROOM RECEPTACLE -COMPLETE WIRING MAKEUP INSIDE ALL BOXES. TIE ALL THE

EQUIPMENT GROUNDING CONDUCTORS TOGETHER WITH WIRE

NUTS. LEAVE OUT MIN. 6" PIGTAILS TO BOND

SWITCHES&RECEPTACLES

Comments: