

PLANNING AND CODES ADMINISTRATION DEPARTMENT
220 SE GREEN STREET
LEE'S SUMMIT, MO 64063
(816) 969-1200 FAX (816) 969-1201

Inspection Summary

Permit #: PRRES20151852, Building Permit - Residential

Address: 617 NW WILLOW DR, Unit:A, LEES SUMMIT, MO 64081617 NW WILLOW DR, Unit:B, LEES SUMMIT, MO 64081617 NW WILLOW DR, Unit:C, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Footing Inspection - Residential	John Borns	Passed	Tuesday, September 15, 2015

Comments: OK TO POUR WHEN READY WALL FOOTINGS & ISOLATED FOOTINGS INCLUDING AT UNITS "B" AND "C". UFER GROUNDING JUMPER IS IN PLACE AT PREVIOUSLY-APPROVED AND POURED UNIT "A" SOUTH END.