

PLANNING AND CODES ADMINISTRATION DEPARTMENT
220 SE GREEN STREET
LEE'S SUMMIT, MO 64063
(816) 969-1200 FAX (816) 969-1201

Inspection Summary

Permit #: PRRES20151242, Building Permit - Residential
Address: 313 SE MILL CREEK DR, LEES SUMMIT, MO 64063

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Electrical Service Inspection - Residential	Mike Copeland	Passed	Tuesday, September 15, 2015
Gas Service Inspection - Residential	Mike Copeland	Failed	Tuesday, September 15, 2015
All Rough Inspection - Residential	Mike Copeland	Failed	Tuesday, September 15, 2015

Corrective Action Required

1	Misc 1	-no interior braced walls installed -corner studs nailing -fill all holes in hangers -security blocking rear door -stud support 2 2x10 over garage door -garage straps -FIRESTOP chases -over drilled studs throughout -multiple top plates drilled over 50% with no reinforcement -nail floor joists from top into plates and sills -fireblock top plate basement -vent basement bar -install plate bolts per code
---	--------	---------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------

Do not insulate.

Comments: