

PLANNING AND CODES ADMINISTRATION DEPARTMENT
220 SE GREEN STREET
LEE'S SUMMIT, MO 64063
(816) 969-1200 FAX (816) 969-1201

Inspection Summary

Permit #: PRCOM20141074, Building Permit - Commercial
Address: 3311 SW KESSLER DR, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

| | | | |
|----------------------------------|--------------|----------|-----------------------------|
| Inspection: | Inspector: | Outcome: | Date: |
| Rated Assembly Inspection | Mark Harding | Failed | Tuesday, September 15, 2015 |

Partial Correction

| | | |
|---|-------------|---|
| 1 | LOWER LEVEL | UNITS FIRST LAYER APPROVED 2 HOUR CONDITIONS APPROVED 2ND LAYER ELEVATOR ROOM APPROVED 3RD AND FOURTH LAYER ELEVATOR ROOM FAILED DUE TO DUCT ELEVATION. STRUCTURAL BEAM STILL NEEDS PROTECTED.>>>1ST LAYER APPROVED. 2 hour conditions approved PLUMBING PENETRATIONS 1-4 MICRO VENT - FAILED 1-4 |
|---|-------------|---|

Comments: