

PLANNING AND CODES ADMINISTRATION DEPARTMENT  
220 SE GREEN STREET  
LEE'S SUMMIT, MO 64063  
(816) 969-1200 FAX (816) 969-1201

## Inspection Summary

---

Permit #: PRCOM20141077, Building Permit - Commercial  
Address: 3341 SW KESSLER DR, LEES SUMMIT, MO 64081

---

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

---

Inspection:	Inspector:	Outcome:	Date:
<b>All Rough Inspection - Commercial</b>	Mark Harding	Failed	Tuesday, September 15, 2015

### Corrective Action Required

1	Misc 1	PREROUGH WALK GARAGES AND GROUND FLOOR NO HVAC STARTED -2ND FLOOR INCOMPLETE HVA, NOT READY FOR INSPECTION 9/4 - ROUGH ON GARAGES AND UNITS, HVAC INCOMPLETE 6000, FIRESTOP BETWEEN ALL UNITS, PUDDY PADS, 4" ROOF DRAIN, SEE NICK FOR OTHER ITEMS CHECK LIST WITH NICK, 1ST FLOOR ITEMS AND 2ND FLOOR INCOMPLETE 1ST FLOOR DRYE VENT NORTH UNIT CORRIDOR WALL NEEDS SHEETROCK BOX. FUR OUT GARAGE I BEAM ON NORTH UNIT
---	--------	--

### Comments: