

PLANNING AND CODES ADMINISTRATION DEPARTMENT
220 SE GREEN STREET
LEE'S SUMMIT, MO 64063
(816) 969-1200 FAX (816) 969-1201

Inspection Summary

Permit #: PRCOM20141080, Building Permit - Commercial
Address: 3371 SW KESSLER DR, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Rated Assembly Inspection	Mark Harding	Partial	Friday, September 18, 2015

Partial Correction

1	FIRST FLOOR	BEHIND TUBS APPROVED CAULKING OF TRAPS THROUGHOUT
---	-------------	--

Partial Correction

2	SECOND FLOOR	BEHIND TUBS APPROVED tub traps
---	--------------	-----------------------------------

Corrective Action Required

3	THIRD FLOOR	tub traps walls ceiling
---	-------------	----------------------------

Corrective Action Required

4	FOURTH FLOOR	tub traps 1ST LAYER CEILING 2HR 1ST LAYER NORTH TOWERUNIT SIDE 2ND LAYERS 2hr walls
---	--------------	---

Corrective Action Required

5	Misc 1	1ST LAYER CEILING stair towers 2nd layers
---	--------	--

Comments: