

PLANNING AND CODES ADMINISTRATION DEPARTMENT
220 SE GREEN STREET
LEE'S SUMMIT, MO 64063
(816) 969-1200 FAX (816) 969-1201

Inspection Summary

Permit #: PRRES20150529, Building Permit - Residential
Address: 3328 SW JESSIE LN, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Gas Service Inspection - Residential	Mike Copeland	Passed	Friday, September 18, 2015

Corrective Action Required

1	Misc 1	-PRESSURE APPROVED
		-BOND GAS PIPE

All Rough Inspection - Residential	Mike Copeland	Partial	Friday, September 18, 2015
---	---------------	---------	----------------------------

Partial Correction

2	Misc 1	APPROVED TO COVER PENDING ENGINEER REPORT
---	--------	---

Comments: