

PLANNING AND CODES ADMINISTRATION DEPARTMENT  
220 SE GREEN STREET  
LEE'S SUMMIT, MO 64063  
(816) 969-1200 FAX (816) 969-1201

## Inspection Summary

---

Permit #: PRRES20151242, Building Permit - Residential  
Address: 313 SE MILL CREEK DR, LEES SUMMIT, MO 64063

---

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

---

Inspection:	Inspector:	Outcome:	Date:
<b>All Rough Inspection - Residential</b>	Mike Copeland	Failed	Monday, September 21, 2015

Corrective Action Required

1	Misc 1	-INSTALL STUD SHOES AND TOP PLATE REINFORCEMENT. -FIRESTOP AREAS WHERE M.E.P. SYSTEMS PREVENT FIREBLOCKING  OKAY INSULATE
---	--------	---

**Comments:**