

PLANNING AND CODES ADMINISTRATION DEPARTMENT
220 SE GREEN STREET
LEE'S SUMMIT, MO 64063
(816) 969-1200 FAX (816) 969-1201

Inspection Summary

Permit #: PRRES20151242, Building Permit - Residential
Address: 313 SE MILL CREEK DR, LEES SUMMIT, MO 64063

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Gas Service Inspection - Residential	Mike Copeland	Passed	Monday, September 21, 2015
All Rough Inspection - Residential	Mike Copeland	Failed	Monday, September 21, 2015

Corrective Action Required

1	Misc 1	-INSTALL STUD SHOES AND TOP PLATE REINFORCEMENT. -FIRESTOP AREAS WHERE M.E.P. SYSTEMS PREVENT FIREBLOCKING OKAY INSULATE
---	--------	---

Comments: