

PLANNING AND CODES ADMINISTRATION DEPARTMENT  
220 SE GREEN STREET  
LEE'S SUMMIT, MO 64063  
(816) 969-1200 FAX (816) 969-1201

## Inspection Summary

---

Permit #: PRRES20151235, Building Permit - Residential  
Address: 3119 SE 3RD TER, LEES SUMMIT, MO 64063

---

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

---

| Inspection:  | Inspector:    | Outcome: | Date:                      |
|--|---------------|----------|----------------------------|
| <b>Electrical Service Inspection - Residential</b> | Mike Copeland | Passed   | Monday, September 21, 2015 |
| <b>Gas Service Inspection - Residential</b>        | Mike Copeland | Passed   | Monday, September 21, 2015 |
| <b>All Rough Inspection - Residential</b>          | Mike Copeland | Failed   | Monday, September 21, 2015 |

### Corrective Action Required

|   |        |  |
|---|--------|--|
| 1 | Misc 1 | -SISTER OVERNOTCHED JOIST OVER FIRST FLOOR BED<br>-INSTALL STUD SHOES, TOP PLATE STRAPS WHERE OVERDRILLED FOR PLUMBING<br>-RE-LOCATE CANS OVER LIVING ROOM NOT IN CONTACT WITH PLUMBING<br>-PROTECT NM CONDUCTORS WITHIN 6 FEET OF ATTIC ACCESS ON RUNNING BOARDS<br>-ATTACH ENGINEER REPORT FOR CORNER STUD FRAMING AT FOYER TO REFLECT THE PLAN AND NOT THE ADDRESS.<br><br>OKAY TO INSULATE |
|---|--------|--|

### Comments: