



FIRE DEPARTMENT

PLAN REVIEW CONDITIONS

September 22, 2015

LUXE ARCHITECTS
10528 CHEROKEE LN
LEAWOOD, KS 66210

Permit No: PRCOM20152145
Project Title: UPS WHITE BOX AT RAINTREE VILLAGE CENTER
Project Address: 833 SW LEMANS LN, LEES SUMMIT, MO 64082
Parcel Number: 70920019500000000
Location: RAINTREE LAKE VILLAGE LOTS 1-6 & TR A ---LOT 6
Type of Work: ALTERATION COMMERCIAL
Occupancy Group: NOT APPLICABLE
Description: ALTERATION TO CONVERT INTO WHITE BOX - OCCUPANCY TO BE GRANTED AT FUTURE TENANT FINISH

The following is a list of requirements from the City of Lee's Summit that have not been satisfactorily addressed in the plans and specifications. Please contact the appropriate department regarding clarification of comments.

Codes Administration (816) 969-1200

Fire Department (816) 969-1300

Building Plan Review

Reviewed By: Joe Frogge

Pending

Fire Plan Review

Reviewed By: Joe Dir

Approved with Conditions

1. 2012 IFC 505.1- Address numbers. New and existing buildings shall have approved address numbers, building numbers or approved building identification placed in a position that is plainly legible and visible from the street or road fronting the property. These numbers shall contrast with their background. In Multi-tenant commercial building where tenants have multiple entrances located on different sides of the building, each door shall be addressed. Address numbers shall be Arabic numerals or alphabet letters. Numbers shall be a minimum of 4 inches (102 mm) high with a minimum stroke width of 0.5 inch (12.7 mm).

POST THE NUMERIC ADDRESS OF THE SUITE (833) ON THE EXTERIOR OF BOTH FRONT AND BACK DOORS. VERIFIED AT INSPECTION.

2. 2012 IFC 901.6- Inspection, testing and maintenance. Fire detection, alarm and extinguishing systems shall be maintained in an operative condition at all times, and shall be replaced or repaired where defective. Not required fire protection systems and equipment shall be inspected, tested and maintained or removed. FIRE SPRINKLER SYSTEM IS TO BE CURRENT WITHIN ONE YEAR OF THE LAST INSPECTION / SERVICE OF THE SYSTEM. VERIFIED AT INSPECTION.

The approval of plans and specifications does not permit the violation of any section of the Building Codes or other City Ordinances or State Law.

The review conducted by the City of Lee's Summit Codes Administration Department shall not be construed as a structural review of the project.