

CODES ADMINISTRATION

PLAN REVIEW CONDITIONS

September 23, 2015

RSA ARCHITECTURE
6335 W 110TH ST
OVERLAND PARK, KS 66211

Permit No: PRCOM20152054
Project Title: BREAKFAST/LUNCH LOVERS RESTAURANT
Project Address: 209 SE GREEN ST, LEES SUMMIT, MO 64063
Parcel Number: 61230151400000000
Location: HOWARDS 1ST ADD TO LEES SUM MIT S 1/2 OF LOTS 6, 7, 8 BLK 18 & W 10' OF S 1/2 OF LOT 9
Type of Work: CHANGE OF TENANT
Occupancy Group: ASSEMBLY FOR FOOD AND DRINK INC BARS, RESTAURANTS, BANQUET HALLS
Description: TENANT FINISH FOR NEW RESTAURANT - INCLUDES NEW TYPE I GREASE HOOD AND EXTERIOR WALK-IN COOLER

Revisions Required

One or more departments have not approved the permit and the following is a list of requirements from the City of Lee's Summit that have not been satisfactorily addressed in the plans and specifications. Please address the comments as requested and provide three (3) copies of any revised sheets and/or additional information. Please contact the appropriate department regarding clarification of comments.

Planning and Codes Administration (816) 969-1200

Fire Department (816) 969-1300

Building Plan Review

Reviewed By: Joe Frogge

Approved with Conditions

1. For the Health Department inspection contact Deb Sees with the Jackson County Public Works Department, Environmental Health Division at (816) 847-7070. Health Department approval is required prior to receiving any type of Occupancy from the City of Lee's Summit.

Action required: Comment is for informational purposes.

3. Building is located in historic downtown area.

Action required: Submit "exterior renovation permit" to Ron Seyl (816-969-1600). Approved exterior renovation permit required prior to issuance of construction permit.

9/23/15 - approved by Planning Department with the following conditions:

1. The rooftop mechanical unit must be totally screened from view per the design plans submitted on September 16, 2015.
2. The outside cooler must be painted the same color as the building.

Fire Plan Review

Reviewed By: Joe Dir

Approved with Conditions

CODES ADMINISTRATION

1. 2012 IFC 1004.3- Posting of occupant load. Every room or space that is an assembly occupancy shall have the occupant load of the room or space posted in a conspicuous place, near the main exit or exit access doorway from the room or space. Posted signs shall be of an approved legible permanent design and shall be maintained by the owner or authorized agent. Post the occupant load of 45 in the area of the main entrance. verified at inspection.

ACKNOWLEDGED IN LETTER SHEET T-1

2. 2012 IFC 505.1- Address numbers. New and existing buildings shall have approved address numbers, building numbers or approved building identification placed in a position that is plainly legible and visible from the street or road fronting the property. These numbers shall contrast with their background. In Multi-tenant commercial building where tenants have multiple entrances located on different sides of the building , each door shall be addressed. Address numbers shall be Arabic numerals or alphabet letters. Numbers shall be a minimum of 4 inches (102 mm) high with a minimum stroke width of 0.5 inch (12.7 mm). Post the numeric address of 209 on the building. Verified at inspection.

ACKNOWLEDGED IN LETTER SHEET T-1

3. 2012 IFC 609.2- Where required. A Type I hood shall be installed at or above all commercial cooking appliances and domestic cooking appliances used for commercial purposes that produce grease vapors. Provide Specs on the ansul supression system to be installed in the kitchen hood. Provide information on the kitchen hood to be intalled, make model.

4. 2012 IFC 901.5- Installation acceptance testing. Fire detection and alarm systems, fire-extinguishing systems, fire hydrant systems, fire standpipe systems, fire pump systems, private fire service mains and all other fire protection systems and appurtenances thereto shall be subject to acceptance tests as contained in the installation standards and as approved by the fire code official. The fire code official shall be notified before any required acceptance testing. The fire code official shall be notified 48 hours before any required acceptance test. Acceptance test required for the kitchen hood ansul fire supression system. To schedule a test contact the fire department 816-969-1300. Information purposes.

5. 2012 IFC 904.11.5- Portable fire extinguishers for commercial cooking equipment. Portable fire extinguishers shall be provided within a 30-foot (9144 mm) travel distance of commercial-type cooking equipment. Cooking equipment involving vegetable or animal oils and fats shall be protected by a Class K rated portable extinguisher. To be mounted under the manul pull station. Verified at inspection.

ACKNOWLEDGED IN LETTER SHEET A-4

6. 2012 IFC 906.5- Conspicuous location. Portable fire extinguishers shall be located in conspicuous locations where they will be readily accessible and immediately available for use. These locations shall be along normal paths of travel, unless the fire code official determines that the hazard posed indicates the need for placement away from normal paths of travel. Provide one 2A-10BC (5lb) fire extinguisher.

Verified at inspection ACKNOWLEDGED IN LETTER SHEET A-1

Licensed Contractors**Reviewed By: Joe Frogge****Rejected**

1. Lee's Summit Code of Ordinance, Section7-130.10 - Business License. It shall be unlawful for any person to engage in the construction contracting business without first obtaining a business license as required under the applicable provisions of Chapter 28 of the Lee's Summit Code of Ordinances.

Action required: Either a Class A or Class B license is required. Provide the name of the licensed general contractor.

2. No person, other than a licensed contractor or employees of a licensed contractor, shall engage in electrical, plumbing or mechanical business, construction, installation or maintenance unless duly licensed in accordance with this section. Excerpt from Sec. 7-130, Lees Summit Code of Ordinances.

CODES ADMINISTRATION

Action required: MEP subcontractors are required to be listed on permit. Provide company names of licensed MEP contractors.

The review conducted by the City of Lee's Summit Codes Administration Department shall not be construed as a structural review of the project.