

PLANNING AND CODES ADMINISTRATION DEPARTMENT
220 SE GREEN STREET
LEE'S SUMMIT, MO 64063
(816) 969-1200 FAX (816) 969-1201

Inspection Summary

Permit #: PRRES20151238, Building Permit - Residential
Address: 265 SE COYLE DR, LEES SUMMIT, MO 64063

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

| Inspection: | Inspector: | Outcome: | Date: |
|---|--------------|----------|----------------------------|
| All Rough Inspection - Residential | Khanh Nguyen | Failed | Friday, September 25, 2015 |

Corrective Action Required

| | | |
|---|--------|---|
| 1 | Misc 1 | -FIREBLOCK FIRESTOP FUR OUTS, TUB TRAPS FUR OUTS 1ST FLOOR STILL HAVE NO FIRESTOPPING. CAN NOT SEE TUB TRAPS DUE TO THE GYP ON THE LID ****25-SEPT-RE-INSPECTION FEE ASSESSED FOR NO ACCESS. PLEASE LEAVE THE ACCESS CODE SO AN INSPECTOR CAN INSPECT |
|---|--------|---|

Comments: