

PLANNING AND CODES ADMINISTRATION DEPARTMENT  
220 SE GREEN STREET  
LEE'S SUMMIT, MO 64063  
(816) 969-1200 FAX (816) 969-1201

## Inspection Summary

---

Permit #: PRCOM20151716, Building Permit - Commercial  
Address: 401 NE COLBERN RD, LEES SUMMIT, MO 64086

---

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

---

Inspection:	Inspector:	Outcome:	Date:
<b>Footing Inspection - Commercial</b>	John Borns	Partial	Tuesday, September 29, 2015

Partial Correction  
1          Misc 1

GRADE BEAM FOR NEW WASH BAYS @ SW OK TO POUR WHEN READY. NO DOWELS SET INTO EXISTING GRADE BEAM; NONE INDICATED ON APPROVED DRAWINGS. JB REFERRED QUESTION TO SPECIAL INSPECTOR PRESENTLY ON JOBSITE -- TO BE DETERMINED BEFORE POUR.

**Comments:**