



FIRE DEPARTMENT

PLANS REVIEW CONDITIONS

Permit No:	PRCOM20152209	Date:	September 29, 2015
Project Title:	SUMMIT PARK CHURCH	Applicant:	
Location:	2818 NE INDEPENDENCE AVE, LEES SUMMIT, MO 64064		ALLIANCE FIRE PROTECTION LLC 130 W 9TH AVE STE 101 KANSAS CITY, MO 64116
Type of Work:			
Occupancy Group:	A-3		
Description:	MODIFY SPACE TO BECOME A CHURCH THAT INCLUDES A WORSHIP CENTER AND CLASSROOMS	Primary:	(913) 888-0647
Construction Type:	Type IIB (Unprotected)		
Map Page:	175R		

Listed below are requirements from our department for the project noted above. If you have any additional questions, please contact our department for further clarification.

Sprinkler Plan Review

Reviewed By: Joe Dir

Released for Construction

1. 2012 IFC 901.5- Installation acceptance testing. Fire detection and alarm systems, fire-extinguishing systems, fire hydrant systems, fire standpipe systems, fire pump systems, private fire service mains and all other fire protection systems and appurtenances thereto shall be subject to acceptance tests as contained in the installation standards and as approved by the fire code official. The fire code official shall be notified before any required acceptance testing. The fire code official shall be notified 48 hours before any required acceptance test. HYDROSTATIC PRESSURE TEST REQUIRED, ACCEPTANCE FLOW TEST REQUIRED. TO SCHEDULE TESTS CONTACT THE FIRE DEPARTMENT AT 818-969-1300

The applicant understands that the requirements listed above must be corrected to conform to applicable City Codes and Ordinances.