

PLANNING AND CODES ADMINISTRATION DEPARTMENT
220 SE GREEN STREET
LEE'S SUMMIT, MO 64063
(816) 969-1200 FAX (816) 969-1201

Inspection Summary

Permit #: PRRES20143037, Building Permit - Residential
Address: 513 NE PROMISED VIEW DR, LEES SUMMIT, MO 64064

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Khanh Nguyen	Not Ready	Thursday, October 01, 2015
Gas Service Inspection - Residential	Khanh Nguyen	Passed	Thursday, October 01, 2015

Comments:

ELECTRICAL NOT READY. GAS TEST APPROVED. TWO PRESSURE GAS SYSTEM: LOWER PRESSURE FOR THE ONE HALF OF HOUSE, AND THE HIGH PRESSURE GAS FOR THE FARTHER HALF OF HOUSE