

CODES ADMINISTRATION

PLAN REVIEW CONDITIONS

October 02, 2015

HEREFORD DOOLEY ARCHITECTS
1720 WEST END AVENUE, SUITE 130
NASHVILLE, TN 37203

Permit No: PRCOM20143335
Project Title: MIDWEST PAIN MANAGEMENT CENTER
Project Address: 200 NE MISSOURI RD, Unit:100, LEES SUMMIT, MO 64086
Parcel Number: 52400043300000000
Location: ROLLINS MEADOWS LOTS 1A & 2A LOT 2A
Type of Work: CHANGE OF TENANT
Occupancy Group: BUSINESS
Description: TENANT BUILD-OUT FOR AN AMBULATORY SURGERY CENTER SPECIALIZING IN OUT PATIENT SURGERY CASES - INCLUDES NEW ENTRY CANOPY AND EXTERIOR EQUIPMENT ENCLOSURE FOR NEW MECHANICAL EQUIPMENT AND GENERATOR

Revisions Required

One or more departments have not approved the permit and the following is a list of requirements from the City of Lee's Summit that have not been satisfactorily addressed in the plans and specifications. Please address the comments as requested and provide three (3) copies of any revised sheets and/or additional information. Please contact the appropriate department regarding clarification of comments.

Planning and Codes Administration (816) 969-1200

Fire Department (816) 969-1300

Building Plan Review

Reviewed By: Joe Frogge

Rejected

5. Minimum parking stall width is 9'-0"

Action required: Revised parking lot striping.

The review conducted by the City of Lee's Summit Codes Administration Department shall not be construed as a structural review of the project.