

PLANNING AND CODES ADMINISTRATION DEPARTMENT
220 SE GREEN STREET
LEE'S SUMMIT, MO 64063
(816) 969-1200 FAX (816) 969-1201

Inspection Summary

Permit #: PRCOM20151716, Building Permit - Commercial
Address: 401 NE COLBERN RD, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

| | | | |
|---|------------|----------|--------------------------|
| Inspection: | Inspector: | Outcome: | Date: |
| Underslab Plumbing Inspection - Commercial | John Borns | Partial | Friday, October 02, 2015 |

Partial Correction
1 Misc 1

OK TO COVER WHEN READY UNDER-SLAB 4" PVC SANITARY
DRAIN & 2" VENT PIPING AT WASH BAYS. NOTE IPC 312
REQUIREMENT FOR PRESSURE-TESTING PIPING SYSTEM.

Comments: