

PLANNING AND CODES ADMINISTRATION DEPARTMENT  
220 SE GREEN STREET  
LEE'S SUMMIT, MO 64063  
(816) 969-1200 FAX (816) 969-1201

## Inspection Summary

---

Permit #: PRCOM20150014, Building Permit - Commercial  
Address: 508 NW MURRAY RD, LEES SUMMIT, MO 64081

---

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

---

Inspection:	Inspector:	Outcome:	Date:
<b>All Rough Inspection - Commercial</b>	John Borns	Partial	Friday, October 02, 2015

Partial Correction  
1 Misc 1

1ST FLOOR:  
OK TO COVER WHEN READY: EXTERIOR WALLS; UNIT WALLS;  
CORRIDOR CEILING AND WALLS; CEILING AT SPACE 111;  
ABOVE-CEILING AND OSB WALL SHEATHING OK TO COVER WHEN  
READY AT 119 & 120 EXCEPT DO NOT COVER PENETRATIONS  
UNTIL APPROVED PER UL DESIGN TO BE SPECIFIED BY A/E;

Partial Correction  
2 Misc 1

2ND FLOOR:  
OK TO COVER WHEN READY: CORRIDOR CEILING; ALL CEILINGS &  
WALLS EXCEPT AT ELEVATOR LOBBY

Partial Correction  
3 Misc 1

3RD FLOOR:  
OK TO COVER WHEN READY: CORRIDOR CEILING; ALL CEILINGS &  
WALLS EXCEPT AT STAIRWELLS & ELEVATOR LOBBY

Partial Correction  
4 Misc 1

4TH FLOOR:  
COMPLETION OF WALL CAVITY FIRE-BLOCKING IN PROGRESS.  
SHIELD/BOCA PLATING OF PLUMBING LINES IN PROGRESS. OK TO  
COVER WHEN READY ALL CEILINGS & WALLS EXCEPT AT  
STAIRWELLS & ELEVATOR LOBBY

Partial Correction  
5 Misc 1

OK TO COVER WHEN READY OSB SHEAR WALL SHEATHING AT:  
EAST STAIRWELL FULL HEIGHT; WEST STAIRWELL FULL HEIGHT;  
**EAST & WEST WALLS AT SPACES 128 & 129;**

**Comments:**