

PLANNING AND CODES ADMINISTRATION DEPARTMENT  
220 SE GREEN STREET  
LEE'S SUMMIT, MO 64063  
(816) 969-1200 FAX (816) 969-1201

## Inspection Summary

Permit #: PRCOM20141080, Building Permit - Commercial  
Address: 3371 SW KESSLER DR, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Rated Assembly Inspection</b>	Mike Copeland	Partial	Friday, October 02, 2015

Partial Correction

1 FIRST FLOOR

BEHIND TUBS APPROVED  
CAULKING OF TRAPS THROUGHOUT

First layer approved throughout including garages

2nd layer approved  
3rd layer equipment room ceiling4TH LAYER

caulking mech plenums approved

Partial Correction

2 SECOND FLOOR

BEHIND TUBS APPROVED  
tub traps

WALLS CEILING  
2hrs

Corrective Action Required

3 THIRD FLOOR

tub traps  
walls ceiling

Corrective Action Required

4 FOURTH FLOOR

tub traps  
1ST LAYER CEILING  
  
2HR  
1ST LAYER NORTH TOWERUNIT SIDE  
2ND LAYERS 2hr walls

STAIRS 1ST LAYER CEILING  
5409

Corrective Action Required

5	THE FOLLOWING AREAS ARE APPROVED	1,2,3 LAYERS NORTH TOWER 1,2,3,4 SOUTH TOWER-
---	-------------------------------------	--

**Comments:**