

PLANNING AND CODES ADMINISTRATION DEPARTMENT
220 SE GREEN STREET
LEE'S SUMMIT, MO 64063
(816) 969-1200 FAX (816) 969-1201

Inspection Summary

Permit #: PRRES20151852, Building Permit - Residential

Address: 617 NW WILLOW DR, Unit:C, LEES SUMMIT, MO 64081617 NW WILLOW DR, Unit:B, LEES SUMMIT, MO 64081617 NW WILLOW DR, Unit:A, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Sewer Service Inspection - Residential	John Borns	Passed	Friday, October 02, 2015
Underslab Plumbing Inspection - Residential	John Borns	Passed	Friday, October 02, 2015

Comments:

OK TO COVER WHEN READY SANITARY SEWER SERVICE INSTALLATION FROM THREE BUILDING ENTRIES TO CONNECTIONS AT STUBS.

OK TO COVER WHEN READY PVC FLOOR DRAIN PIPING AT CRAWL SPACES TWO LOCATIONS. NOTE IPC 312 / IRC P2503.5.1 REQUIREMENT FOR PRESSURE-TESTING PIPING SYSTEM.