

PLANNING AND CODES ADMINISTRATION DEPARTMENT
220 SE GREEN STREET
LEE'S SUMMIT, MO 64063
(816) 969-1200 FAX (816) 969-1201

Inspection Summary

Permit #: PRCOM20152091, Building Permit - Commercial
Address: 13 SE 3RD ST, LEES SUMMIT, MO 64063

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Commercial	John Borns	Passed	Friday, October 02, 2015

Comments: OK TO COVER WHEN READY WALL & CEILING FRAMING + CONCEALED SYSTEMS ROUGH.

COURTESY OBSERVATION IN ADVANCE OF FINAL INSPECTION: NEC 370-20 SET-BACK OF ELECTRICAL RECEPTACLE / SWITCH BOXES: MUST BE FLUSH WITH COMBUSTIBLE WALL SURFACE; 1/4" MAXIMUM SET-BACK @ NON-COMBUSTIBLE SURFACES.