

CODES ADMINISTRATION

PLAN REVIEW CONDITIONS

October 02, 2015

CAMM CONSTRUCTION INC
PO BOX 1417
LEES SUMMIT, MO 64063

Permit No: PRCOM20152145
Project Title: UPS WHITE BOX AT RAINTREE VILLAGE CENTER
Project Address: 833 SW LEMANS LN, LEES SUMMIT, MO 64082
Parcel Number: 70920019500000000
Location: RAINTREE LAKE VILLAGE LOTS 1-6 & TR A ---LOT 6
Type of Work: ALTERATION COMMERCIAL
Occupancy Group: NOT APPLICABLE
Description: ALTERATION TO CONVERT INTO WHITE BOX - OCCUPANCY TO BE GRANTED AT FUTURE
TENANT FINISH

The following is a list of requirements from the City of Lee's Summit that have not been satisfactorily addressed in the plans and specifications. Please contact the appropriate department regarding clarification of comments.

Codes Administration (816) 969-1200

Fire Department (816) 969-1300

Licensed Contractors

Reviewed By: Joe Frogge

Approved

Building Plan Review

Reviewed By: Joe Frogge

Approved with Conditions

1. 2012 IPC 403.1 – Minimum number of fixtures. Plumbing fixtures shall be provided for the type of occupancy and in the minimum number shown in Table 403.1. types of occupancies not shown in Table 403.1 shall be considered individually by the code official. The number of occupants shall be determined by the International Building Code. Occupancy classification shall be determined in accordance with the International Building Code.

Action required: Comment is for informational purposes. It may be deemed necessary to install a service sink prior to issuing subsequent tenant finish permit. At this point it is assumed that floor will be carpeted. If this is not the intent, a service sink is required.

Fire Plan Review

Reviewed By: Joe Dir

Approved with Conditions

1. 2012 IFC 505.1- Address numbers. New and existing buildings shall have approved address numbers, building numbers or approved building identification placed in a position that is plainly legible and visible from the street or road fronting the property. These numbers shall contrast with their background. In Multi-tenant commercial building where tenants have multiple entrances located on different sides of the building , each door shall be addressed. Address numbers shall be Arabic numerals or alphabet letters. Numbers shall be a minimum of 4 inches (102 mm) high with a minimum stroke width of 0.5 inch (12.7 mm).

POST THE NUMERIC ADDRESS OF THE SUITE ON THE EXTERIOR OF BOTH FRONT AND BACK DOORS. VERIFIED AT INSPECTION.

2. 2012 IFC 901.6- Inspection, testing and maintenance. Fire detection, alarm and extinguishing systems shall be maintained in an operative condition at all times, and shall be replaced or repaired where defective. Not required fire protection

systems and equipment shall be inspected, tested and maintained or removed.

FIRE SPRINKLER SYSTEM IS TO BE CURRENT WITHIN ONE YEAR OF THE LAST INSPECTION / SERVICE OF THE SYSTEM. VERIFIED AT INSPECTION.

- ☒ Approved to issue per the listed conditions.
☐ Do not issue per the listed conditions.
☐ Approved to construct foundation only per the listed conditions.
☐ Requires Final Development Plan approval prior to issuing this building permit.

The applicant agrees to incorporate the aforementioned requirements into the project to conform to applicable City Codes and Ordinances.

Signature of Applicant

Date

Print Applicant Name

CompanyName

The approval of plans and specifications does not permit the violation of any section of the Building Codes or other City Ordinances or State Law.

The review conducted by the City of Lee's Summit Codes Administration Department shall not be construed as a structural review of the project.