

PLANNING AND CODES ADMINISTRATION DEPARTMENT  
220 SE GREEN STREET  
LEE'S SUMMIT, MO 64063  
(816) 969-1200 FAX (816) 969-1201

## Inspection Summary

---

Permit #: PRCOM20141080, Building Permit - Commercial  
Address: 3371 SW KESSLER DR, LEES SUMMIT, MO 64081

---

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

---

Inspection:	Inspector:	Outcome:	Date:
<b>Above Ceiling Inspection</b>	Mark Harding	Failed	Monday, October 05, 2015

Corrective Action Required

1	Misc 1	1ST FLOOR FAILED 2ND NOT READY 4th not ready drops D1 units
---	--------	---

<b>Rated Assembly Inspection</b>	Mark Harding	Partial	Monday, October 05, 2015
----------------------------------	--------------	---------	--------------------------

Partial Correction

1	FIRST FLOOR	BEHIND TUBS APPROVED CAULKING OF TRAPS THROUGHOUT First layer approved throughout including garages 2nd layer approved 3rd layer equipment room ceiling 4TH LAYER caulking mech plenums approved b,1,2,3-ok plenums
---	-------------	--

Partial Correction

2	SECOND FLOOR	BEHIND TUBS APPROVED tub traps
---	--------------	-----------------------------------

WALLS CEILING  
2hrs

Corrective Action Required

3	THIRD FLOOR	tub traps walls ceiling
---	-------------	----------------------------

Corrective Action Required

4	FOURTH FLOOR	tub traps 1ST LAYER CEILING
---	--------------	--------------------------------

2HR  
1ST LAYER NORTH TOWERUNIT SIDE  
2ND LAYERS 2hr walls

STAIRS 1ST LAYER CEILING  
5409

Corrective Action Required

5 THE FOLLOWING AREAS  
ARE APPROVED

1,2,3 LAYERS NORTH TOWER  
1,2,3,4 SOUTH TOWER-

**Comments:**