

PLANNING AND CODES ADMINISTRATION DEPARTMENT  
220 SE GREEN STREET  
LEE'S SUMMIT, MO 64063  
(816) 969-1200 FAX (816) 969-1201

## Inspection Summary

---

Permit #: PRCOM20150014, Building Permit - Commercial  
Address: 508 NW MURRAY RD, LEES SUMMIT, MO 64081

---

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

---

Inspection:	Inspector:	Outcome:	Date:
<b>All Rough Inspection - Commercial</b>	John Borns	Partial	Wednesday, October 07, 2015
Partial Correction 1 Misc 1		1ST FLOOR: OK TO COVER WHEN READY: EXTERIOR WALLS; UNIT WALLS; CORRIDOR CEILING AND WALLS; CEILING AT SPACE 111; ABOVE-CEILING AND OSB WALL SHEATHING OK TO COVER WHEN READY AT 119 & 120 EXCEPT DO NOT COVER PENETRATIONS UNTIL APPROVED PER UL DESIGN TO BE SPECIFIED BY A/E;	
Partial Correction 2 Misc 1		2ND FLOOR: OK TO COVER WHEN READY: CORRIDOR CEILING; ALL CEILINGS & WALLS EXCEPT AT ELEVATOR LOBBY	
Partial Correction 3 Misc 1		3RD FLOOR: OK TO COVER WHEN READY: CORRIDOR CEILING; ALL CEILINGS & WALLS EXCEPT AT STAIRWELLS & ELEVATOR LOBBY	
Partial Correction 4 Misc 1		4TH FLOOR: COMPLETION OF WALL CAVITY FIRE-BLOCKING IN PROGRESS. SHIELD/BOCA PLATING OF PLUMBING LINES IN PROGRESS. OK TO COVER WHEN READY ALL CEILINGS & WALLS EXCEPT AT STAIRWELLS & ELEVATOR LOBBY	
Partial Correction 5 Misc 1		OK TO COVER WHEN READY OSB SHEAR WALL SHEATHING AT: EAST STAIRWELL FULL HEIGHT; WEST STAIRWELL FULL HEIGHT; EAST & WEST WALLS AT SPACES 128 & 129;	
Partial Correction 6 Misc 1		<b>OK TO COVER WHEN READY ELEVATOR LOBBY CEILINGS AND WALLS AT 4TH FLOOR; 3RD FLOOR; 2ND FLOOR;</b>	

**Comments:**