PLANNING AND CODES ADMINISTRATION DEPARTMENT
220 SE GREEN STREET
LEE'S SUMMIT, MO 64063
(816) 969-1200 FAX (816) 969-1201

Inspection Summary

Permit #: PRRES20151229, Building Permit - Residential
Address: 404 SE MILL CREEK DR, LEES SUMMIT, MO 64063

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Electrical Service Inspection - Residential	Mike Copeland	Passed	Wednesday, October 07, 2015
All Rough Inspection - Residential	Mike Copeland	Failed	Wednesday, October 07, 2015

Corrective Action Required

1	Misc 1	-GARAGE PORTAL NOT NAILED 3" O.C. -INSTALL H CLIPS FOR TRUSSES BEARING ON GARAGE COLD WALL. -SEAL ALL PENETRATIONS BETWEEN FLOORS AND TO ATTIC. -NAIL GORDER TRUSS OVER KITCHEN PER PLAN. -PROTECT CONDUCTORS CORNERS OF FRONT FIRST FLOOR BEDROOM. -BRACE TRUSSES PER PLANS. -FIREBLOCK BASEMENT BACK WALL BY BAR. -STUD SHOES AT PLUMBING BASEMENT BACK WALL BY BAR. OKAY TO INSULATE

Gas Service Inspection - Residential	Mike Copeland	Passed	Wednesday, October 07, 2015

Comments: