



LEE'S SUMMIT
MISSOURI



FIRE DEPARTMENT

PLANS REVIEW CONDITIONS

Permit No: PRCOM20151735 Date: October 08, 2015
Project Title: LEE'S SUMMIT MEDICAL CENTER Applicant:
O.R. ADDITION REMODEL
Location: SIEMENS INDUSTRY INC
2100 SE BLUE PKWY, LEES P O BOX 80600
SUMMIT, MO 64063 INDIANAPOLIS, IN 46280
Type of Work:
Occupancy Group: I-2 Primary: (317) 596-3260 Ext: 2368
Description: OPERATING ROOM ADDITION
AND INTERIOR ALTERATIONS
Construction Type: Type IB
Map Page:

Listed below are requirements from our department for the project noted above. If you have any additional questions, please contact our department for further clarification.

Alarm Plan Review

Reviewed By: Joe Dir

Released for Construction

1. 2012 IFC 901.5- Installation acceptance testing. Fire detection and alarm systems, fire-extinguishing systems, fire hydrant systems, fire standpipe systems, fire pump systems, private fire service mains and all other fire protection systems and appurtenances thereto shall be subject to acceptance tests as contained in the installation standards and as approved by the fire code official. The fire code official shall be notified before any required acceptance testing. The fire code official shall be notified 48 hours before any required acceptance test.

The applicant understands that the requirements listed above must be corrected to conform to applicable City Codes and Ordinances.