

PLANNING AND CODES ADMINISTRATION DEPARTMENT  
220 SE GREEN STREET  
LEE'S SUMMIT, MO 64063  
(816) 969-1200 FAX (816) 969-1201

## Inspection Summary

---

Permit #: PRCOM20152239, Building Permit - Commercial  
Address: 200 NE TUDOR RD, LEES SUMMIT, MO 64086

---

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

---

Inspection:	Inspector:	Outcome:	Date:
<b>Final Building Inspection - Commercial</b>	John Borns	Partial	Thursday, October 08, 2015

Corrective Action Required

1	Misc 1	1-1/2" DIFFERENTIAL FROM TOP OF THRESHOLD TO CONCRETE SLAB TO BE RESOLVED.
---	--------	---

**Comments: GLAZING IS SAFETY GLASS. EXIT SIGN TESTED OK. ONLY ISSUE ABOVE TO BE DISCUSSED.**