

PLANNING AND CODES ADMINISTRATION DEPARTMENT  
220 SE GREEN STREET  
LEE'S SUMMIT, MO 64063  
(816) 969-1200 FAX (816) 969-1201

## Inspection Summary

Permit #: PRCOM20150014, Building Permit - Commercial  
Address: 508 NW MURRAY RD, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Rated Assembly Inspection</b>	John Borns	Partial	Friday, October 09, 2015
Partial Correction 1 Misc 1		1ST FLOOR: OK TO TAPE, MUD & FIRE-STOP: RATED CEILINGS AND WALLS AT ALL UNITS ELEVATOR MACHINE ROOM; E108; CORRIDOR CEILING AND WALLS; 119 EXCEPT SOUTH WALL; 120 EXCEPT NORTH WALL;	
Partial Correction 2 Misc 1		2ND FLOOR: OK TO TAPE, MUD & FIRESTOP: CORRIDOR CEILING AND WALLS; RATED CEILINGS AND WALLS AT: ALL UNITS; 208; 219; 220;	
Partial Correction 3 Misc 1		3RD FLOOR: OK TO TAPE, MUD & FIRE-STOP ONE LAYER 5/8" TYPE X GWB AT: CORRIDOR CEILING; ELECT & DATA RMS WALLS. WALLS AND CEILINGS AT UNITS 302*; 311; 312*; 313; 314; 315; 317; 318; 321; 323; 324; 327; 332; 333; CORRIDOR WALLS; 319; 320;  *EXCEPT ROOF DRAINS & STAIRWELL WALLS STAIRWELL WALLS NOT READY FOR INSPECTION	
Partial Correction 4 Misc 1		4TH FLOOR: OK TO TAPE, MUD & FIRE-STOP ONE LAYER 5/8" TYPE X GWB AT: UNITS 412; 413*; 414*; 423; 424; 427*; CORRIDOR WALLS ONLY ; E428; E429; 411; 419; 420; <b>CORRIDOR CEILING</b>	
Corrective Action Required 5 Misc 1		PROTECTION OF PENETRATIONS TO BE SPECIFIED BY A/E;	
<b>All Rough Inspection - Commercial</b>	John Borns	Partial	Friday, October 09, 2015

Partial Correction

1 Misc 1

1ST FLOOR:

OK TO COVER WHEN READY: EXTERIOR WALLS; UNIT WALLS; CORRIDOR CEILING AND WALLS; CEILING AT SPACE 111; ABOVE-CEILING AND OSB WALL SHEATHING OK TO COVER WHEN READY AT 119 & 120 EXCEPT DO NOT COVER PENETRATIONS UNTIL APPROVED PER UL DESIGN TO BE SPECIFIED BY A/E;

Partial Correction

2 Misc 1

2ND FLOOR:

OK TO COVER WHEN READY: CORRIDOR CEILING; ALL CEILINGS & WALLS EXCEPT AT ELEVATOR LOBBY

Partial Correction

3 Misc 1

3RD FLOOR:

OK TO COVER WHEN READY: CORRIDOR CEILING; ALL CEILINGS & WALLS EXCEPT AT STAIRWELLS & ELEVATOR LOBBY

Partial Correction

4 Misc 1

4TH FLOOR:

COMPLETION OF WALL CAVITY FIRE-BLOCKING IN PROGRESS. SHIELD/BOCA PLATING OF PLUMBING LINES IN PROGRESS. OK TO COVER WHEN READY ALL CEILINGS & WALLS EXCEPT AT STAIRWELLS & ELEVATOR LOBBY

Partial Correction

5 Misc 1

OK TO COVER WHEN READY OSB SHEAR WALL SHEATHING AT: EAST STAIRWELL FULL HEIGHT; WEST STAIRWELL FULL HEIGHT; EAST & WEST WALLS AT SPACES 128 & 129;

Partial Correction

6 Misc 1

**OK TO COVER WHEN READY ELEVATOR LOBBY CEILINGS AND WALLS AT 4TH FLOOR; 3RD FLOOR; 2ND FLOOR; 1ST FLOOR**

**Comments:**