



**LEE'S SUMMIT**  
**MISSOURI**



**FIRE DEPARTMENT**

**PLANS REVIEW CONDITIONS**

Permit No:	PRCOM20151716	Date:	October 12, 2015
Project Title:	LEE'S SUMMIT HONDA	Applicant:	
Location:	401 NE COLBERN RD, LEES SUMMIT, MO 64086	ALLIANCE FIRE PROTECTION LLC 130 W 9TH AVE STE 101 KANSAS CITY, MO 64116	
Type of Work:			
Occupancy Group:	B		
Description:	ADDITION OF 3 CAR WASH BAYS - ADDITION OF 3 SERVICE BAYS - INTERIOR ALTERATIONS	Primary: (913) 888-0647	
Construction Type:	Type IIB (Unprotected)		
Map Page:			

**Listed below are requirements from our department for the project noted above. If you have any additional questions, please contact our department for further clarification.**

**Sprinkler Plan Review**

**Reviewed By: Joe Dir**

**Released for Construction**

1. 2012 IFC 901.6- Inspection, testing and maintenance. Fire detection, alarm and extinguishing systems shall be maintained in an operative condition at all times, and shall be replaced or repaired where defective. Not required fire protection systems and equipment shall be inspected, tested and maintained or removed.  
FIRE SPRINKLER SYSTEM SHALL BE CURRENT ON ITS ANNUAL SERVICE, VERIFIED AT INSPECTION

**The applicant understands that the requirements listed above must be corrected to conform to applicable City Codes and Ordinances.**