

PLANNING AND CODES ADMINISTRATION DEPARTMENT  
220 SE GREEN STREET  
LEE'S SUMMIT, MO 64063  
(816) 969-1200 FAX (816) 969-1201

## Inspection Summary

---

Permit #: PRCOM20141074, Building Permit - Commercial  
Address: 3311 SW KESSLER DR, LEES SUMMIT, MO 64081

---

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

---

Inspection:	Inspector:	Outcome:	Date:
<b>Rated Assembly Inspection</b>	Mark Harding	Partial	Monday, October 12, 2015

Partial Correction

1	LOWER LEVEL	UNITS FIRST LAYER APPROVED 2 HOUR CONDITIONS APPROVED 2ND LAYER ELEVATOR ROOM APPROVED 3RD AND FOURTH LAYER ELEVATOR ROOM FAILED DUE TO DUCT ELEVATION. STRUCTURAL BEAM STILL NEEDS PROTECTED.>>>1ST LAYER APPROVED. HVAC PENETRATIONS 1-4 2 hour conditions approved PLUMBING PENETRATIONS 1-4 MICRO VENT - FAILED 1-4 elevators wall-outside ok , inside 1,2
---	-------------	--

Comments: