



**FIRE DEPARTMENT**

**PLANS REVIEW CONDITIONS**

Permit No: PRCOM20152209 Date: October 13, 2015  
Project Title: SUMMIT PARK CHURCH Applicant:  
Location: 2818 NE INDEPENDENCE AVE, <NO CONTACT NAME AVAILABLE>  
LEES SUMMIT, MO 64064 <NO CONTACT INFORMATION AVAILABLE>

Type of Work:  
Occupancy Group: A-3  
Description: MODIFY SPACE TO BECOME A CHURCH THAT INCLUDES A WORSHIP CENTER AND CLASSROOMS  
FIRE ALARM SOLUTIONS  
3150 MERCIER STREEET STE 520  
KANSAS CITY, MO 64111

Construction Type: Type IIB (Unprotected) Primary: (816) 753-4660  
Map Page: 175R

**Listed below are requirements from our department for the project noted above. If you have any additional questions, please contact our department for further clarification.**

**Alarm Plan Review**

**Reviewed By: Joe Dir**

**Released for Construction**

2. 2012 IFC 901.5- Installation acceptance testing. Fire detection and alarm systems, fire-extinguishing systems, fire hydrant systems, fire standpipe systems, fire pump systems, private fire service mains and all other fire protection systems and appurtenances thereto shall be subject to acceptance tests as contained in the installation standards and as approved by the fire code official. The fire code official shall be notified before any required acceptance testing. The fire code official shall be notified 48 hours before any required acceptance test.  
TO SCHEDULE A TEST PRIOR TO THE FINAL OCCUPANCY INSEPTION CONTACT THE FIRE DEPARTMENT AT 816-969-1300

**The applicant understands that the requirements listed above must be corrected to conform to applicable City Codes and Ordinances.**