

PLANNING AND CODES ADMINISTRATION DEPARTMENT
220 SE GREEN STREET
LEE'S SUMMIT, MO 64063
(816) 969-1200 FAX (816) 969-1201

Inspection Summary

Permit #: PRCOM20143335, Building Permit - Commercial
Address: 200 NE MISSOURI RD, Unit:100, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Commercial	John Borns	Failed	Wednesday, October 14, 2015

Corrective Action Required

- | | | |
|---|--------|--|
| 1 | Misc 1 | ELECTRICAL RECEPTALCES AT FOUR EXAM ROOMS: TWO LESS THAN 6' FROM EDGE OF SINK AT EACH ROOM NOT GFCI-PROTECTED. |
| 2 | Misc 1 | SAFETY GLASS TO BE VERIFIED WHEN GLAZING IS COMPLETED. |
| 3 | Misc 1 | "NO SMOKING" SIGNS REQUIRED AT PUBLIC ENTRANCE DOORS. |
| 4 | Misc 1 | LABELED DOORS A143b, A151 AND A155 SUBJECT TO APPROVAL WHEN INSTALLED PERMANENT. |
| 5 | Misc 1 | REQUIREMENT FOR OPENING DEVICE AT WEST MAIN ENTRANCE TO BE DETERMINED. |
| 6 | Misc 1 | RESOLVE ANY FIRE DEPARTMENT ISSUES. |
| 7 | Misc 1 | OCCUPANCY STATUS: OK TO SET UP FOR BUSINESS. NO PUBLIC OR PATIENTS PRIOR TO APPROVAL. |

Comments: