

PLANNING AND CODES ADMINISTRATION DEPARTMENT
220 SE GREEN STREET
LEE'S SUMMIT, MO 64063
(816) 969-1200 FAX (816) 969-1201

Inspection Summary

Permit #: PRCOM20150781, Building Permit - Commercial
Address: 2801 NE MCBAINE DR, LEES SUMMIT, MO 64064

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Above Ceiling Inspection	Khanh Nguyen	Failed	Wednesday, October 14, 2015

Corrective Action Required

1	Misc 1	-COMPLETE ALL MECHANICAL DUCTING TO CEILING -SUPPORT GRID EVERY 4 FT THROUGHOUT -SECURELY FASTEN ALL MC WIRING, OTHER THAN THE ONE DIRECTLY GOING TO THE CEILING LIGHTS, WITHIN 12" OF BOXES; SECURELY FASTEN ALL EMT WITHIN 3 FT OF JUNCTION BOXES -SUPPORT CEILING LIGHTS. TWO WIRE SUPPORT AT OPPOSITE CORNERS -COMPLETE FIRE SPRINKLER INSTALLATION
---	--------	------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------

Underground Electrical Inspection - Commercial	Khanh Nguyen	Failed	Wednesday, October 14, 2015
-------------------------------------------------------	--------------	--------	-----------------------------

Corrective Action Required

1	Misc 1	-LIGHT POLE PIERS AND GROUNDING WERE NOT INSPECTED
---	--------	----------------------------------------------------

Gas Piping Inspection - Commercial	Khanh Nguyen	Failed	Wednesday, October 14, 2015
-------------------------------------------	--------------	--------	-----------------------------

Corrective Action Required

1	Misc 1	-SUPPORT GAS LINE ON ROOF TOP PER CODE. MAXIMUM INTERVAL OF 8 FT FOR 3/4" PIPE AND 10 FT FOR LARGER THAN 1" PIPE
---	--------	------------------------------------------------------------------------------------------------------------------

Gas Service Inspection - Commercial	Khanh Nguyen	Passed	Wednesday, October 14, 2015
--------------------------------------------	--------------	--------	-----------------------------

In-wall Inspection

Khanh Nguyen

Passed

Wednesday, October 14, 2015

Comments: