

PLANNING AND CODES ADMINISTRATION DEPARTMENT
220 SE GREEN STREET
LEE'S SUMMIT, MO 64063
(816) 969-1200 FAX (816) 969-1201

Inspection Summary

Permit #: PRCOM20141077, Building Permit - Commercial
Address: 3341 SW KESSLER DR, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Rated Assembly Inspection	Mark Harding	Partial	Thursday, October 15, 2015

Corrective Action Required

1	Misc 1	1ST LAYER INSIDE ELEVATOR ELEVATOR CEILING-1ST,2,3, 4 LAYERS APPROVED SOUTH TOWER 1ST LAYER NORTH TOWER 1-2 1ST LAYER 2nd layer partial - CORRIDOR CEILING 2ND LAYER 1,2,3 TUB WALLS- 2HR TUB WALLS 1ST,2ND LAYERS units 1st layer 1st floor unit side 1st layer 2nd,3,4th ceiling only	
Partial Correction	2	FIRST FLOOR	1st floor garage need to enclose north garage i beam 2ND LAYER 2 HOUR CONDITIONS APPROVED
Partial Correction	3	SECOND FLOOR	2ND LAYER 2 HOUR CONDITIONS APPROVED
Partial Correction	4	THIRD FLOOR	1ST LAYER WALLS AND CEILING APPROVED 2hr walls- unit bathrooms 6304,6305,6306 nail pattern
Partial Correction	5	FOURTH FLOOR	1ST LAYER WALLS AND CEILING APPROVED

Comments: