

PLANNING AND CODES ADMINISTRATION DEPARTMENT  
220 SE GREEN STREET  
LEE'S SUMMIT, MO 64063  
(816) 969-1200 FAX (816) 969-1201

## Inspection Summary

---

Permit #: PRCOM20150658, Building Permit - Commercial  
Address: 2751 NE DOUGLAS ST, Unit:R, LEES SUMMIT, MO 64064

---

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

---

Inspection:	Inspector:	Outcome:	Date:
<b>Gas Piping Inspection - Commercial</b>	Khanh Nguyen	Passed	Friday, October 16, 2015

<b>Occupancy Inspection - Codes Commercial</b>	Khanh Nguyen	Temporary C of O	Friday, October 16, 2015
--	--------------	------------------	--------------------------

Corrective Action Required

1	Misc 1	-WATER DEPT APPROVAL REQUIRED -INSTALL SEWER CLEANOUT PLUG -VENT PLUMBING TO OUTDOOR -SECURE RACEWAY AT FRONT EXTERIOR DOOR PER CODE -BOND BUILDING STEEL TO THE SERVICE GROUNDING BUS BAR OR ENCLOSURE WITH #4 COPPER -GFCI AT WET BAR NOT TRIPPING -STAIR GUARDRAIL (MIN 42") AND HANDRAIL ON BOTH SIDES
---	--------	--

<b>Occupancy Inspection - Fire</b>	Michael Weissenbach	Passed	Friday, October 16, 2015
------------------------------------	---------------------	--------	--------------------------

Comments: