

PLANNING AND CODES ADMINISTRATION DEPARTMENT  
220 SE GREEN STREET  
LEE'S SUMMIT, MO 64063  
(816) 969-1200 FAX (816) 969-1201

## Inspection Summary

---

Permit #: PRCOM20152209, Building Permit - Commercial  
Address: 2818 NE INDEPENDENCE AVE, LEES SUMMIT, MO 64064

---

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

---

Inspection:	Inspector:	Outcome:	Date:
<b>In-wall Inspection</b>	Khanh Nguyen	Failed	Friday, October 16, 2015

Corrective Action Required

1	Misc 1	-SECURE ALL MC WITHIN 12" OF BOXES -PROTECT PLUMBING IN RESTROOM WHERE INSTALLED WITHIN 1.5" OF STUD/PLATE SURFACE
---	--------	--

**Comments:**