

PLANNING AND CODES ADMINISTRATION DEPARTMENT  
220 SE GREEN STREET  
LEE'S SUMMIT, MO 64063  
(816) 969-1200 FAX (816) 969-1201

## Inspection Summary

---

Permit #: PRRES20151229, Building Permit - Residential  
Address: 404 SE MILL CREEK DR, LEES SUMMIT, MO 64063

---

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

---

Inspection:	Inspector:	Outcome:	Date:
<b>All Rough Inspection - Residential</b>	Mike Copeland	Failed	Monday, October 19, 2015

### Corrective Action Required

1	Misc 1	-INSTALL H CLIPS FOR TRUSSES BEARING ON GARAGE COLD WALL.
		-BRACE TRUSSES PER PLANS.
		-STUD SHOES AT PLUMBING BASEMENT BACK WAALL
		OKAY TO INSULATE

### Comments: