

PLANNING AND CODES ADMINISTRATION DEPARTMENT  
220 SE GREEN STREET  
LEE'S SUMMIT, MO 64063  
(816) 969-1200 FAX (816) 969-1201

## Inspection Summary

---

Permit #: PRCOM20141077, Building Permit - Commercial  
Address: 3341 SW KESSLER DR, LEES SUMMIT, MO 64081

---

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

---

Inspection:	Inspector:	Outcome:	Date:
<b>Rated Assembly Inspection</b>	Mark Harding	Partial	Monday, October 19, 2015

### Corrective Action Required

1	Misc 1	1ST LAYER INSIDE ELEVATOR ELEVATOR CEILING-1ST,2,3, 4 LAYERS APPROVED SOUTH TOWER 1ST LAYER NORTH TOWER 1-2 1ST LAYER 2nd layer partial - CORRIDOR CEILING 2ND LAYER 1,2,3 TUB WALLS- 2HR TUB WALLS 1ST,2ND LAYERS units 1st layer 1st floor unit side 1st layer 2nd,3,4th ceiling only
Partial Correction		
2	FIRST FLOOR	1st floor garage need to enclose north garage i beam 2ND LAYER 2 HOUR CONDITIONS APPROVED
Partial Correction		
3	SECOND FLOOR	2ND LAYER 2 HOUR CONDITIONS APPROVED
Partial Correction		
4	THIRD FLOOR	1ST LAYER WALLS AND CEILING APPROVED 2hr walls- unit bathrooms 6304,6305,6306 nail patterN 2ND LAYER WALLS @ 2 HR CONDITIONS - 3RD FLOOR; 1ST LAYER CORRIDORS STAIR TOWERS AT SIDE ENTRY;
Partial Correction		
5	FOURTH FLOOR	1ST LAYER WALLS AND CEILING APPROVED 2ND LAYER

<b>Above Ceiling Inspection</b>	Mark Harding	Failed	Monday, October 19, 2015
---------------------------------	--------------	--------	--------------------------

Corrective Action Required

1	THE FOLLOWING AREAS ARE APPROVED	PENDING  CORRIDORS- INSTALL CAN LIGHTS, GOOGLE SUPPORTED OFF OF SPRINKLER LINES, COMPLETE HVAC  D1 UNITS FLOORS-  4TH FLOOR DROPS-
---	-------------------------------------	--

**Comments:**