



**LEE'S SUMMIT**  
MISSOURI

**CODE MODIFICATION REQUEST**

(PLAN REVIEW)

BUILDING/STRUCTURE NAME: HANGAR R

PREMISE ADDRESS: 2751 NE DOUGLAS ST. LSMO 64064

PERMIT NUMBER (if applicable): PRCOM 20150658

OWNER'S NAME: Property LEASW LLC

TO: Director of Planning & Codes Administration

In accordance with the Lee's Summit Building Code, I wish to apply for a modification to one or more provisions of the code as I feel that the spirit and intent of the Lee's Summit Building Code are observed the public health, welfare and safety are assured. The following articulates my request for your review and action. (NOTE: ATTACH ANY ADDITIONAL INFORMATION NECESSARY)

SUBMITTED BY:

NAME: Bill Barnard

ADDRESS: 1516 SW 1602 RD

CITY, STATE, ZIP: Lee's Summit, MO 64064

( ) OWNER ☒ OWNER'S AGENT

Tel.# (816) 215-0891

SIGNATURE: [Signature]

TRACY DEISTER - ASST. DIRECTOR CODES ADMINISTRATION: ☒ APPROVAL ( ) DENIAL

SIGNATURE: [Signature] DATE: 10-19-15

ROBERT MCKAY - DIRECTOR OF PLANNING & CODES ADMIN: ☒ APPROVED ( ) DENIED

SIGNATURE: [Signature] DATE: 10-19-15

COMMENTS: Rise is 7 1/4" vs 7" for Commercial / STAIRS are only used to go to a storage area in a private hangar not for public use. STAIRS WERE BUILT AS PERFECT RESIDENTIAL STAIRS. A COPY MUST BE ATTACHED TO THE APPROVED PLANS ON THE JOB SITE Located in a private hangar not open to public & stairs only serve storage area. RJD  
2/18/14 M:\CODES ADMIN\Forms and Handouts\Codes\Forms\Code Modification Request PLAN REVIEW.doc